



AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant:	FarLight L.L.C.	Manufacturer:	FarLight L.L.C.
Address:	846 Watson Avenue, Unit A Wilmington, CA 90744	Address:	846 Watson Avenue, Unit A Wilmington, CA 90744
Country:	USA	Country:	USA
Contact:	Mr. Steve Becerra	Contact:	Mr. Steve Becerra
Phone:	(310) 830-0181	Phone:	(310) 830-0181
FAX:	(310) 830-9066	FAX:	(310) 830-9066
Email:	sbecerra@farlight.com	Email:	sbecerra@farlight.com

Party Authorized To Apply Mark: Same as Manufacturer
Report Issuing Office: Richardson, Texas

Control Number: 3026589 **Authorized by:** *Michelle Lake*
for William T. Starr, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
165 Main Street, Cortland, NY 13045
Telephone 800-345-3851 or 607-753-6711 Fax 607-756-6699

Standard(s):	Luminaires, ANSI/UL 1598, 3rd Edition, 09/17/08 and CSA C22.2 No. 250.0-08, 3rd Ed. Luminaires for Use in Hazardous (Classified) Locations, ANSI/ UL 844, 12th Ed., 01/11/06-Revised 11/20/08 Electric Luminaires for Use in Hazardous Locations, CSA C22.2 No. 137-1981 including general instruction 1 through 3 1982 Outline of Investigation For Light Emitting Diode (LED) Light Sources For Use In Lighting Products, UL Subject 8750 - Issue Number: 3, 07/22/08 Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations (ANSI/ISA-12.12.01-2007); Non-incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations (CSA C22.2 No. 213-M1987 (Reaffirmed 2008))
Product:	Red Obstruction Lights For use in: Class I, Division 2, Groups A, B, C, D, hazardous locations. Temperature Code: T4A Ambient Temperature Range: -40 to 55°C (-40 to 130°F)



AUTHORIZATION TO MARK

Models:	L-810LED1HL-AAAA-B L-864LED3.1HL-XXXX-Y
----------------	--